

ADDENDUM NO. 2

NDOR Operations Building No. 00101 Emergency Generator Install
AFE I-050

TO ALL WHO HAVE RECEIVED PLANS AND SPECIFICATIONS FOR THE REFERENCED PROJECT.

General:

1. Attachment:

- A. Pre-Bid Attendance List.

Specifications:

2. Refer to Section 263213 – DIESEL ENGINE GENERATORS:

- A. Clarification to Part 3 – EXECUTION, 3.5 FIELD QUALITY CONTROL, Paragraph K: Contractor does not need to purchase the fuel to fill the belly tank. Existing fuel from the existing 4000 gallon storage tank will be used.

3. Refer to Section 260533 – RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS:

- A. Add the following to Part 3 – EXECUTION, 3.1 RACEWAY APPLICATION, Paragraph B:
“6. All new conduit installed inside electrical room 018 shall be rigid steel conduit.”

Plans:

4. Refer to Plan Sheet E0.1:

- A. Contractor shall locate and protect communication service line that runs from overhead power pole to boiler room and crosses the path of the new conduits to the generator.

5. Refer to Plan Sheet E1.1:

- A. Add the following to the end of Sheet Note #1: “Contractor shall encase the service conduit in 2” of concrete.”
- B. Clarification associated with spare conduit from new generator: Spare 4” conduit from generator shall be terminated just inside of room. It is not required to extend all the way to the ATS.

6. Refer to Plan Sheet E1.2:

- A. Clarification associated with Remote Generator Annunciator Panel in Room 1206: Annunciator and associated conduit may be surface mounted to existing wall inside of room.

7. Refer to Plan Sheet E2.1:

- A. Change MSD panel from a Main Lug Only (MLO) to a panel with an 800 amp Main Circuit Breaker with LSI adjustable settings.

Each Bidder must acknowledge receipt of all addenda in the space provided on the Proposal Form.



OLSSON ASSOCIATES
ENGINEERS • PLANNERS • SCIENTISTS • SURVEYORS

ATTENDANCE RECORD

Pre-Bid Meeting
NDOR Operations Building No. 00101
Emergency Generator Install
5001 S. 14th Street, Lincoln, NE
OA Project No. 016-0721
Aug. 30th, 2016 2:00PM

601 P St. Suite 200 § Lincoln, Nebraska 68508 § 402/474-6311

Name of Attendees (Please Print)	Company Representing and Address	Phone No.	Fax No.
Dow Petri	Kidwell 3333 Folkway Circ	402-473-7783	402-475-9186
Austin Pohlmann	CCE 4220 Lucile Dr. Stel	402-420-7435	402-420-7436
JARED BURHAM	DICKET-HINDS-MUIR	402-421-6000	402-421-6021
Tony Dush	Grogg Electric Co	402-476-6463	402-476-6491
JOSH QUILLMAN	Cummins	715-225-3043	651-286-2214
TIM HICKS	Commonwealth Elec	402 474 1341	402 474-0114
JEFF HOLL	HY-Electric	402-466-6000	(402) 4641575
Paul Scheel	Mu Electric	" "	" "
Mark Henry	Empire Electric	402-416-5197	" "